INTRA DEPARTMENTAL REVIEW MEMO

0036581

- ☐ STAGE I DRAWINGS
- ☐ STAGE II DRAWINGS
- ☐ CONTRACT DRAWINGS
- ☒ SPECIFICATIONS
- ☐ ALTERATION APPLICATION
- ☐ PAI
- ☐ O&M STANDARD
- ☐ OTHER FV

A: Messrs. Kirk, Shelton
Louis A. Cavanna
February 13, 1969
ECT: WORLD TRADE CENTER - CONTRACT WTC-113.00 - SPRAY ON FIRE PROOFING NORTH AND SOUTH TOWERS

ITIONAL INFORMATION: (INCLUDE PROJECT COORDINATOR, RESPONSIBLE DEPARTMENT)

LEASE REVIEW THE ABOVE MATERIAL AND RETURN COMMENTS BY AM/PM ON 2/18/69 TO 1201

COMMENTS:

Specifications - General

1. It is required that the spray fiber material be listed by U.L.

2. It is required that the sprayed-on-fire-proofing should conform to the latest changes of the New York City Administrative Building Code as indicated in the November 15, 1968 rulings of the Board of Standards and Appeals (copy attached).

Joseph S. Rand
Engineer
Inspection and Safety Division

JSR:gh

PLAINTIFF'S EXHIBIT PX-605

DIVISION HEAD

DATE

NOTE: USE EXTRA SHEETS FOR ADDITIONAL COMMENTS